

CERTIFICATE OF COMPLIANCE WITH THE ORDER 2.1

According to EN 10204

The HERZ Gate Valve **4 4113 7x, 8x** is made of Ductile Iron, and with stainless steel stem. The Wedge is made of rubber plated ductile iron. Within the scope of the HERZ quality assurance the material, size and function-tests, concerning the spare parts and the whole product, are in accordance with EN ISO:9008.

MATERIAL:

| | |
|-----------|-------------------------|
| Body Type | Ductile Iron, GJS 500-7 |
| Bonnet | Ductile Iron, GJS 500-7 |
| Stem | Stainless steel |
| Wedge | Ductile Iron, GJS 500-7 |

FUNCTION:

General measurements according HERZ datasheet
Design Standard: EN 1171
Max. operation pressure: 16bar
Temperature range: -10°C up to 80°C
Flange Dimensions according to EN 1092-2

HERZ Armaturen
Ges.m.b.H. Richard Strauss-Straße 22
A-1232 Wien

11.10.2024



Ing. Wolfgang Rauch
Quality Manager