



## CERTIFICATE OF COMPLIANCE WITH THE ORDER 2.1

According to EN 10204

The HERZ Gate Valve **4 4113 5x** is made of Ductile Iron, and with stainless steel stem. The Wedge is made of rubber plated ductile iron. Within the scope of the HERZ quality assurance the material, size and function-tests, concerning the spare parts and the whole product, are in accordance with EN ISO:9008.

### **MATERIAL:**

|           |                         |
|-----------|-------------------------|
| Body Type | Ductile Iron, GJS 500-7 |
| Bonnet    | Ductile Iron, GJS 500-7 |
| Yoke      | Ductile Iron, GJS 500-7 |
| Stem      | Stainless steel.        |
| Wedge     | Ductile Iron, GJS 500-7 |

### **FUNCTION:**

|   |                  |
|---|------------------|
| General measurements according HERZ datasheet |                  |
| Design Standard:                              | EN 5163          |
| Max. operation pressure:                      | 10bar            |
| Shell Test Pressure                           | 24bar            |
| Temperature range:                            | -10°C up to 80°C |

Flange Dimensions according to EN 1092-2

HERZ Armaturen  
Ges.m.b.H. Richard Strauss-  
Straße 22  
A-1232 Wien

15.01.2024



Ing.Wolfgang  
Rauch Quality  
Manager