



CERTIFICATE OF COMPLIANCE WITH THE ORDER 2.1

According to EN 10204

The HERZ-Metering Station **1 4000 0X** with two test points are used for hydraulic balance of cooling systems, fan coils and heating systems. Two measuring valves are mounted, presetting by limitation of valve lift, pipe connection with external thread on both sides, with flat seal.

MATERIAL:

Body (upper part, lower part) DZR copper alloy, CW602N according EN 12420
Brass turned part DZR copper alloy, CW602N according EN 12164
Seals EPDM

CONTROL:

Each delivery valve is tested to impermeability and the valve is permanently embossed with the test mark.

FUNCTION:

Technical data (adjustments, ...) according Herz standard sheet
The control of products (material, dimensional, and functional tests) during production is performed in accordance to the requirements of the EN ISO 9001:2008 certified Quality Management System.

Vienna, the 22nd of Oct, 2021

HERZ Armaturen Ges.m.b.H



Ing. Wolfgang Rauch
Quality Manager